Telephone 0484-2623576
email -qcsdlankamaly@gmail com

KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB, ANKAMALY (NABL RECOGNIZED)

WATER TEST REPORT

Report Issue Date:01.06.2026

Customer Name &Address	**Date of Receipt of Payment**	**11.05.2026**
ST ANNES PUBLIC SCHOOL VATHAKKAD THURAVOUR P O ANGAMALY	**Date of Sample received**	**23.05.2026**
	Sample Given by	**MO FHC THURAVOOR**
	Sample Code	**ANK/483/05/2026**
	Sample Name	**DRINKING WATER**
	Sample Condition	**Fit For Analysis**
	Source of Sample	**BORE WELL**
	Sample Quantity	**2 Litre**
	Test performing dates : From: 25.05.2026 To: 25.05.2026	

Sl.No	Characteristics	Unit	Test Methods	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-1984(Reaffirmed 2017)	1.0	1.04
2	pH at 25^{O}C	–	IS 3025 (Part 11)2022	6.5 to 8.5	7.1
3	Electrical Conductivity	micromhos/cm	IS 3025(part14)-2013(Reaffirmed 2019)	–	144
4	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	66
5	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	18.2
6	Iron (as Fe)	mg/L	IS 3025(part 53) - 2003(Reaffirmed 2019)	1	0.17
7	Nitrate (as NO3)	mg/L	APHA 4500-NO3- B 2012	45	BDL(DL=1)

Remarks:-

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

End of Report

KERALA WATER AUTHORITY QUALITY CONTROL SUB DISTRICT LAB ANKAMALY

Analysed By

FATHIMA FAIROOS

Technical Manager

email:-qcsdlankamaly@gmail.com

KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB, ANKAMALY

WATER ANALYSIS REPORT

Report Issue Date: 01.06.2026

REPORT NO : ANK/483/05/2026-27

Customer Name &Address	**Date of Receipt of Payment**	**11.05.2026**
ST ANNES PUBLIC SCHOOL VATHAKKAD THURAVOUR P O ANGAMALY	**Date of Sample received**	**23.05.2026**
	Sample Given by	**MO FHC THURAVOOR**
	Sample Code	**ANK/BC 100/05/26**
	Sample Name	**DRINKING WATER**
	Source of Sample	**BORE WELL**
	Sample Quantity	**200ml**
	Test performing dates : From: 25.05.2026 To: 26.05.2026	

Sl. No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	Absent
2	E-Coli	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	Absent

Remarks:-

NB:-The result stated above related only to the sample(s) submitted for testing by the customer .The test certificate shall not be reproduced except in full without the written approval of the Laboratory

End of Report

KERALA WATER AUTHORITY QUALITY CONTROL SUB DISTRICT LAB ANKAMALY

Authorized By

FASEELA KAREEM
Bacteriologist